

## BRE Global

### Notified Body No. 0832

BRE Global Limited  
Bucknalls Lane, Garston, Watford,  
Hertfordshire, UK, WD25 9XX  
Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
Web: [www.breglobal.com](http://www.breglobal.com)

## Certificate of constancy of performance

### 0832-CPR-F2557

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

#### NFXI-VIEW High Sensitivity Point Optical Smoke Detector with Short Circuit Isolator

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

and produced in the manufacturing plant(s):

**Notifier by Honeywell (Pittway Systems Technology Group (Europe) Ltd)**  
**Via Caboto 19/3**  
**34147 Trieste**  
**Italy**

**Pittway Tecnologica Srl**  
**Via Caboto 19/3**  
**34147 Trieste**  
**Italy**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

**EN 54-7:2000 + A1:2002 + A2:2006 - Smoke detectors - Point detectors**  
**EN 54-17:2005 - Short circuit isolators**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### **the constancy of performance of the construction product.**

This certificate was first issued on 14 March 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Manager,

On behalf of BRE Global Limited

Date of First Issue: 14 March 2019

Date of Issue: 14 March 2019

Issue number 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).

**BRE Global Limited**

Bucknalls Lane,  
Garston, Watford,  
Hertfordshire, UK,  
WD25 9XX

**Notified Body No. 0832**

Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
web: [www.breglobal.com](http://www.breglobal.com)

**APPENDIX to Certificate of constancy of performance: 0832-CPR-F2557**

**NFXI-VIEW High Sensitivity Point Optical Smoke Detector with Short Circuit Isolator**

**Base:**

B501AP Intelligent Sensor Base

**Note:**

1. Meets the requirements of EN 54-7:2000 at high sensitivity



P Halligan, Certification Manager,

On behalf of BRE Global Limited

Date of First Issue: 14 March 2019

Date of Issue: 14 March 2019

Issue number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).