LPCB®

www.redbooklive.com

Certificate of Product Approval

Certificate Number: 1139e Issue: 01

Teletek Electronics JSC

14A Srebarna Street
Sofia
1407
Bulgaria

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products	Standards
Alarm Warning Devices	**EN 54-3:2001 +A1:2002 +A2:2006**
SensoIRIS WSOU IS-R	**EN 54-17: 2005**
SensoIRIS BSOU IS	
SensoIRIS BSST IS	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB	Verifier	Date of Issue	Date of First Issue
	P Halligan	13 October 2016	13 October 2016

This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

 © BRE Global Ltd, 2016

80018

LPCB®

Appendix to Certificate No: 1139e

Issue: 01

Teletek Electronics JSC

Certified Product	Description	LPCB Ref.No.
SensoIRIS WSOU IS-R	Intelligent Analogue Addressable Fire Alarm Type A Indoor Sounder with built-in Short Circuit Isolator Module Notes: 1. Approved to Type A Indoor only. 2. Meets the requirements of EN 54-3 and approved at the following tone: - Tone 27, 2400Hz – 2900Hz @ 3Hz high volume only	1139e/01
SensoIRIS BSOU IS	Intelligent Analogue Addressable Fire Alarm Type A Base Sounder with built-in Short Circuit Isolator Module Notes: 1. Approved to Type A Indoor only. 2. Meets the requirements of EN 54-3 and approved at the following tone: - Tone 27, 2400Hz – 2900Hz @ 3Hz high volume only	1139e/02
SensoIRIS BSST IS	Intelligent Analogue Addressable Fire Alarm Type A Base Sounder Strobe/Flash with built-in Short Circuit Isolator Module Notes: 1. Approved to Type A Indoor only. 2. Meets the requirements of EN 54-3 and approved at the following tone: - Tone 27, 2400Hz – 2900Hz @ 3Hz high volume only	1139e/03

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB	Verifier	Date of Issue	Date of First Issue
	P Halligan	13 October 2016	13 October 2016

This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

 © BRE Global Ltd, 2016

80018