EVPÚ®

NOTIFIED BODY No. 1293

EC – CERTIFICATE OF CONFORMITY

No. 1293 – CPD – 0259

on December 19, 2011

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive – CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

Module Conventional Zone SensoIRIS MC

is an addressable module designed for application in addressable fire alarm system, supporting TTE-SensoIRIS communicaqtion protocol

placed on the market by

TELETEK ELECTRONICS JSC
14A Srebarna Str., 1407 Sofia, Bulgaria

and produced in the factory

TELETEK ELECTRONICS JSC
14A Srebarna Str., 1407 Sofia, Bulgaria

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the approved body EVPÚ a.s., Notified Body No. 1293 has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the Standard (resp. in)

EN 54-18: 2005/AC: 2007

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on December 19, 2011 and remains valid as long as the conditions laid down in the harmonized technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

EVPÚ a.s. Nová Dubnica Notified Body No. 1293

Marek Hudák

The CE 1293 Marking may only be used if conformity with all relevant and effective Directives of EP and Council is attested.

040644