

Certificate

of
Continued Compliance

No: 162351918/AA/02

In compliance with the procedure specified in the Alarm Components Scheme, Telefication declares that the stated alarm equipment complies with the Technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: **2-way keyfob LoNa**
Trademark: **Interlogix**
Type designation: **RF-4041-07-2**
Serial No: **N/A**
Hardware / Software version: **Rev1 / ESW1123-01-D01.hex**

Manufacturer: **UTC Fire & Security B.V.**
Address: **Kelvinstraat 7**
City: **6003DH Weert**
Country: **Netherlands**

This certificate is granted to:

Name: **UTC Fire & Security B.V.**
Address: **Kelvinstraat 7**
City: **6003DH Weert**
Country: **Netherlands**

Expiry date: **27 February 2024**

This certificate has THREE Annexes.

Zevenaar, 27 February 2020



Martin van Balveren
Product Assessor



Remarks and observations

The following conditions are applicable:

Security Grade: 2

Environmental class: II

Equipment class: Portable

Power supply type: C

According to EN 50131-1:2006, this equipment can be applied in installed systems up to and including security grade 2.

Electromagnetic emission and safety aspects are not covered by this certificate.

Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- Telefication: 161001036-003-Ver 1.00, 20 April 2017
- Telefication: 161001036-001-Ver 1.00, 20 April 2017
- Telefication B.V.: 200200611-001-Ver 1.00, 27 February 2020

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-3	March, 2009
------------	-------------

Applied Standards

EN 50130-5	June, 2011
EN 50131-5-3	March, 2017
EN 50131-6	October, 2017
EN 50130-4+A1	October, 2014
EN 50131-1+A1+A2	May, 2017

The product as described in this certificate includes the following type designations:

- Product description: 2-way keyfob LoNa
- Trademark: Interlogix
- Type designation: RF-4041-07-2
- Hardware version: Rev1
- Software version: ESW1123-01-D01.hex
- Serial number: N/A