

INCERT CERTIFICATE

Certificate No: C-001-1481

In compliance with the procedure specified in the INCERT Scheme, Telefication declares that the stated alarm equipment complies with the Technical standards and specifications as listed in this certificate.

Product description: **16 Zone Expander Module**

Trademark: **Interlogix**

Type designation: **NX-216E-EN**

Serial No: **N/A**

Hardware / Software version: **38-0002 revB / 755-3066**

Variants: **See Annex 3**

Manufacturer: **UTC Fire & Security B.V.**

Address: **Kelvinstraat 7**

City: **6003DH Weert**

Country: **Netherlands**

This certificate is granted to:

Name: **UTC Fire & Security EMEA bvba**

Address: **De Kleetlaan 3**

City: **1831 Diegem**

Country: **Belgia**

Expiry date: **16 February 2026**

This INCERT certificate has THREE Annexes and is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standards. It does not imply an assessment on the whole production. Conformity of the produced products with the specimen tested remains on the full responsibility of the manufacturer.

Zevenaar, 17 February 2020



Jan Willem Verwoert
Project Manager



Remarks and observations

The following conditions are applicable:

Category: Interface

Security grade: 2

Environmental class: II

Equipment class: Fixed

Factory location:

UTC Fire & Security México corporation, S. de R.L. de
C.V.

Boulevard 1 Eje C Parque Industrial

Navojoa

Mexico

Documentation lodged for this INCERT certificate

Test Reports:

- Telefication B.V.: 181100707-005-Ver 2.00, 13 February 2020
- Telefication: 20094538800 - Rev. 4, 08 March 2011
- ANPI asbl: bis-rec-698 add 11 UTC NX216 NX216EEN NX216Z8 NX507E NX508E NX534E, 28 October 2016
- Telefication B.V.: 181100707-ENV-Ver 3.00, 13 February 2020
- Telefication B.V.: 181100707-008-Ver. 2.00, 13 February 2020

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

T 031+A1

February, 2018

Applied Standards

EN 50130-5

June, 2011

EN 50131-3

March, 2009

EN 50130-4+A1

October, 2014

EN 50131-1+A1+A2

May, 2017

The product as described in this certificate includes the following type designations:

- Product description:	16 Zone Expander Module
- Trademark:	Interlogix
- Type designation:	NX-216E-EN
- Hardware version:	38-0002 revB
- Software version:	755-3066
- Serial number:	N/A

- Product description:	8 Zone Expander Module
- Trademark:	Interlogix
- Type designation:	NX-216Z8
- Hardware version:	38-0002 revB
- Software version:	755-A0024-E3D3
- Serial number:	N/A