

The PA2 is a double push panic button. The several versions are listed as below:

- PA2EW – Double End Push PA, White
- PA2ES – Double End Push, Steel fascia, Black body
- PA2SW – Double Side Push, White
- PA2SS – Double Side Push, Steel fascia, Black body

No matter the configuration, the internal wiring and installation remains the same. All units listed above are latching PAs – as such they require a key to reset.

INSTALLATION

- Screw the unit base to mounting surface.
- Connect your alarm circuit wires to the PA contacts. This will create the circuit. Once the button is pressed in the circuit will be broken.
- Attach your tamper wires to the tamper terminals. If the lid is removed the tamper will activate.
- Other terminals are spare.
- Carefully fit the lid to the central post on the base.
- Ensure no snagging occurs.
- Operation: Push both buttons inwards. The microswitch will only operate when both buttons are pushed simultaneously.
- Reset by using the reset key (supplied)

Note the diagrams below for the end and side push versions:

